

序号	报告编号	发布日期	结论	影像资料
225	GX-B1354/20-2-23004	2023. 4. 25	电网接地电容电流符合规定	
226	GX-B1322/21-2-23113~23114	2023. 4. 26	本次共检验电力电缆2条，2条所检项目合格。	
227	GX-B1500/21-2-23039	202. 4. 27	所检项目合格	

228	GX-B1383/21-2-23004	2023. 4. 27	综合判定：合格	 <p>2023/04/20</p>
229	GX-B1383/21-2-23005	2023. 4. 27	综合判定：合格	 <p>2023/04/20</p>
230	GX-B1383/21-2-23006	2023. 4. 27	综合判定：不合格	 <p>2023/04/20</p>

231	GX-B1563/21-2-23003	2023. 4. 27	所检项目合格	 2023/03/22
232	GX-B1495/20-2-23193-23201	2023. 4. 25	所检项目合格	 2023/04/16
233	GX-B1495/20-2-23202-23213	2023. 4. 25	所检项目合格	 2023/04/16

234	GX-B1520/20-2-23007	2023. 4. 27	综合判定：合格	
235	GX-B1383/21-2-23002	2023. 4. 28	综合判定：合格	
236	GX-B1383/21-2-23003	2023. 4. 28	综合判定：合格	

237	GX-B1329/21-2-23095~23106	2023. 4. 28	所检项目合格		
238	GX-B1307/20-2-23049	2023. 4. 28	综合判定：合格。		
239	GX-B1308/21-2-23009	2023. 4. 28	所检项目合格		

240	GX-B1499/21-2-23040	2023. 4. 28	所检项目合格			
241	GX-B1499/21-2-23041	2023. 4. 28	所检项目合格			
242	GX-B1499/21-2-23042	2023. 4. 28	所检项目合格			

243	GX-B1308/21-2-23010	2023. 4. 28	所检项目合格			
244	GX-B1499/21-2-23043	2023. 4. 28	所检项目合格			
245	GX-B1499/21-2-23044	2023. 4. 28	所检项目合格			

246	GX-B1499/21-2-23045	2023. 4. 28	所检项目合格		 <p>2023/04/12</p>	
247	GX-B1515/22-2-23006	2023. 4. 28	所检项目合格		 <p>2023/04/11</p>	
248	GX-B1308/21-2-23008	2023. 4. 28	所检项目合格		 <p>2023-04-15</p>	

249	GX-B1499/21-2-23037	2023. 4. 28	除吨水百米电耗不符合标准要求外，其余所检项目合格		 2023-04-15	
250	GX-B1499/21-2-23038	2023. 4. 28	除吨水百米电耗不符合标准要求外，其余所检项目合格		 2023-04-15	
251	GX-B1499/21-2-23039	2023. 4. 28	除吨水百米电耗不符合标准要求外，其余所检项目合格		 2023-04-15	

252	GX-B1404/20-2-23006	2023. 4. 28	<p>所检电网谐波电压总谐波畸变率、各次谐波电压含有率、谐波电流符合 GB/T 14549-1993 《电能质量 公用电网谐波》要求。</p>		
253	GX-B1404/20-2-23007	2023. 4. 28	<p>所检电网谐波电压总谐波畸变率、各次谐波电压含有率、谐波电流符合 GB/T 14549-1994 《电能质量 公用电网谐波》要求。</p>		