







| 序号 | 报告编号                      | 发布日期       | 结论                                     | 影像资料                                                                                 |
|----|---------------------------|------------|----------------------------------------|--------------------------------------------------------------------------------------|
| 91 | GX-B1495/20-3-24613~24620 | 2024年3月21日 | 本次共检高压开关设备<br>8台，8台高压开关设备所检<br>项目合格。   |   |
| 92 | GX-B1495/20-3-24581~24595 | 2024年3月21日 | 本次共检高压开关设备<br>15台，15台高压开关设备所<br>检项目合格。 |   |
| 93 | GX-B1495/20-3-24596~24612 | 2024年3月21日 | 本次共检高压开关设备<br>17台，17台高压开关设备所<br>检项目合格。 |  |

|    |                           |            |                                        |                                                                                      |
|----|---------------------------|------------|----------------------------------------|--------------------------------------------------------------------------------------|
| 94 | GX-B1495/20-3-24627~24630 | 2024年3月21日 | 本次共检高压开关设备<br>4台，4台高压开关设备所检<br>项目合格。   |   |
| 95 | GX-B1495/20-3-24621~24626 | 2024年3月21日 | 本次共检高压开关设备<br>6台，6台高压开关设备所检<br>项目合格。   |   |
| 96 | GX-B1495/20-3-24570~24580 | 2024年3月21日 | 本次共检高压开关设备<br>11台，11台高压开关设备所<br>检项目合格。 |  |


|    |                     |             |         |                                                                                                                                                                                                                                                                                                                                                                                                                                 |  |
|----|---------------------|-------------|---------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--|
| 97 | GX-B1310/21-3-24024 | 2024. 3. 25 | 符合标准要求。 |  A photograph showing two workers in safety gear (hard hats, high-visibility vests) standing on a metal platform or scaffolding. One worker is wearing a red helmet and the other an orange one. They appear to be inspecting or working on a structure. A yellow timestamp '2024.03.10' is visible in the bottom right corner of the image. |  |
| 98 | GX-B1427/21-3-24004 | 2024. 3. 25 | 符合标准要求。 |  A photograph showing a worker in safety gear (hard hat, high-visibility vest) standing on a metal platform or scaffolding. The worker is wearing a red helmet and an orange high-visibility vest. They are looking down at something in their hands. A yellow timestamp '2024.03.10' is visible in the bottom right corner of the image.    |  |
| 99 | GX-B1310/21-3-24029 | 2024. 3. 25 | 符合标准要求。 |  A photograph showing a worker in safety gear (hard hat, high-visibility vest) working on a large, green, curved structure, possibly a part of a machine or a large container. The worker is wearing a red helmet and an orange high-visibility vest. A yellow timestamp '2024.3.15' is visible in the bottom right corner of the image.    |  |

|     |                     |             |         |  |                                                                                      |
|-----|---------------------|-------------|---------|--|--------------------------------------------------------------------------------------|
| 100 | GX-B1427/21-3-24007 | 2024. 3. 25 | 符合标准要求。 |  |   |
| 101 | GX-B1328/20-3-24022 | 2024. 3. 25 | 合格      |  |   |
| 102 | GX-B1328/20-3-24023 | 2024. 3. 25 | 合格      |  |  |


|     |                           |             |                                      |  |                                                                                      |  |
|-----|---------------------------|-------------|--------------------------------------|--|--------------------------------------------------------------------------------------|--|
| 103 | GX-B1328/20-3-24024       | 2024. 3. 25 | 合格                                   |  |   |  |
| 104 | GX-B1495/20-3-24434~24442 | 2024. 3. 25 | 本次共检高压开关设备<br>9台，9台高压开关设备所检<br>项目合格。 |  |   |  |
| 105 | GX-B1495/20-3-24443~23450 | 2024. 3. 25 | 本次共检高压开关设备<br>8台，8台高压开关设备所检<br>项目合格。 |  |  |  |


|     |                           |             |                                        |                                                                                      |
|-----|---------------------------|-------------|----------------------------------------|--------------------------------------------------------------------------------------|
| 106 | GX-B1495/20-3-24451~24461 | 2024. 3. 25 | 本次共检高压开关设备<br>11台，11台高压开关设备所<br>检项目合格。 |   |
| 107 | GX-B1495/20-3-24462~24468 | 2024. 3. 25 | 本次共检高压开关设备<br>7台，7台高压开关设备所检<br>项目合格。   |   |
| 108 | GX-B1495/20-3-24469~24483 | 2024. 3. 25 | 本次共检高压开关设备<br>15台，15台高压开关设备所<br>检项目合格。 |  |

|     |                           |             |                                |                                                                                      |  |
|-----|---------------------------|-------------|--------------------------------|--------------------------------------------------------------------------------------|--|
| 109 | GX-B1495/20-3-24484~24509 | 2024. 3. 25 | 本次共检高压开关设备26台，26台高压开关设备所检项目合格。 |   |  |
| 110 | GX-B1495/20-3-24510~24520 | 2024. 3. 25 | 本次共检高压开关设备11台，11台高压开关设备所检项目合格。 |   |  |
| 111 | GX-B1495/20-3-24521~24533 | 2024. 3. 25 | 本次共检高压开关设备13台，13台高压开关设备所检项目合格。 |  |  |


|     |                           |             |                            |  |                                                                                      |  |
|-----|---------------------------|-------------|----------------------------|--|--------------------------------------------------------------------------------------|--|
| 112 | GX-B1321/20-3-24579~24581 | 2024. 3. 26 | 本次共检电力电缆3条，3条电力电缆所检项目合格。   |  |   |  |
| 113 | GX-B1321/20-3-24567~24578 | 2024. 3. 26 | 本次共检电力电缆12条，12条电力电缆所检项目合格。 |  |   |  |
| 114 | GX-B1321/20-3-24330~24339 | 2024. 3. 27 | 所检项目合格                     |  |  |  |


|     |                           |             |        |  |                                                                                      |  |
|-----|---------------------------|-------------|--------|--|--------------------------------------------------------------------------------------|--|
| 115 | GX-B1321/20-3-24340~24349 | 2024. 3. 27 | 所检项目合格 |  |   |  |
| 116 | GX-B1321/20-3-24350~24359 | 2024. 3. 27 | 所检项目合格 |  |   |  |
| 117 | GX-B1321/20-3-24360~24369 | 2024. 3. 27 | 所检项目合格 |  |  |  |


|     |                           |             |        |                                                                                      |
|-----|---------------------------|-------------|--------|--------------------------------------------------------------------------------------|
| 118 | GX-B1321/20-3-24370~24381 | 2024. 3. 27 | 所检项目合格 |   |
| 119 | GX-B1321/20-3-24382~24394 | 2024. 3. 27 | 所检项目合格 |   |
| 120 | GX-B1321/20-3-24395~24404 | 2024. 3. 27 | 所检项目合格 |  |

|     |                           |             |                            |                                                                                      |
|-----|---------------------------|-------------|----------------------------|--------------------------------------------------------------------------------------|
| 121 | GX-B1321/20-3-24405~24413 | 2024. 3. 27 | 所检项目合格                     |   |
| 122 | GX-B1321/20-3-24414~24421 | 2024. 3. 27 | 所检项目合格                     |   |
| 123 | GX-B1321/20-3-24440~24454 | 2024. 3. 27 | 本次共检电力电缆15条，15条电力电缆所检项目合格。 |  |


|     |                           |             |                            |  |                                                                                      |
|-----|---------------------------|-------------|----------------------------|--|--------------------------------------------------------------------------------------|
| 124 | GX-B1321/20-3-24455~24467 | 2024. 3. 27 | 本次共检电力电缆13条，13条电力电缆所检项目合格。 |  |   |
| 125 | GX-B1321/20-3-24468~24483 | 2024. 3. 27 | 本次共检电力电缆16条，16条电力电缆所检项目合格。 |  |   |
| 126 | GX-B1321/20-3-24484~24491 | 2024. 3. 27 | 本次共检电力电缆8条，8条电力电缆所检项目合格。   |  |  |

|     |                           |             |                          |                                                                                     |
|-----|---------------------------|-------------|--------------------------|-------------------------------------------------------------------------------------|
| 127 | GX-B1321/20-3-24492~24497 | 2024. 3. 27 | 本次共检电力电缆6条，6条电力电缆所检项目合格。 |  |
| 128 | GX-B1321/20-3-24498~24501 | 2024. 3. 27 | 本次共检电力电缆4条，4条电力电缆所检项目合格。 |  |
| 129 | GX-B1328/20-3-24038       | 2024. 3. 28 | 本次共检绝缘手套2只，2只绝缘手套合格。     |                                                                                     |
| 130 | GX-B1328/20-3-24039       | 2024. 3. 28 | 本次共检绝缘鞋2只，2只绝缘鞋合格。       |                                                                                     |
| 131 | GX-B1328/20-3-24036       | 2024. 3. 28 | 本次共检绝缘手套2只，2只绝缘手套合格。     |                                                                                     |

|     |                           |             |                            |                                                                                      |
|-----|---------------------------|-------------|----------------------------|--------------------------------------------------------------------------------------|
| 132 | GX-B1328/20-3-24037       | 2024. 3. 28 | 本次共检绝缘鞋2只，2只绝缘鞋合格。         |                                                                                      |
| 133 | GX-B1328/20-3-24040       | 1×1         | 2024. 3. 28                | 本次共检绝缘手套2只，2只绝缘手套合格。                                                                 |
| 134 | GX-B1328/20-3-24041       | 1×1         | 2024. 3. 28                | 本次共检绝缘鞋2只，2只绝缘鞋合格。                                                                   |
| 135 | GX-B1321/20-3-24511~24520 | 2024年3月28日  | 本次共检电力电缆10条，10条电力电缆所检项目合格。 |   |
| 136 | GX-B1321/20-3-24521~24531 | 2024年3月28日  | 本次共检电力电缆11条，11条电力电缆所检项目合格。 |  |

|     |                           |            |                            |                                                                                      |
|-----|---------------------------|------------|----------------------------|--------------------------------------------------------------------------------------|
| 137 | GX-B1321/20-3-24532~24543 | 2024年3月28日 | 本次共检电力电缆12条，12条电力电缆所检项目合格。 |   |
| 138 | GX-B1321/20-3-24544~24550 | 2024年3月28日 | 本次共检电力电缆7条，7条电力电缆所检项目合格。   |   |
| 139 | GX-B1321/20-3-24551~24555 | 2024年3月28日 | 本次共检电力电缆5条，5条电力电缆所检项目合格。   |  |

|     |                           |            |                            |                                                                                      |
|-----|---------------------------|------------|----------------------------|--------------------------------------------------------------------------------------|
| 140 | GX-B1321/20-3-24556~24566 | 2024年3月28日 | 本次共检电力电缆11条，11条电力电缆所检项目合格。 |   |
| 141 | GX-B1328/20-3-24019       | 2024年3月28日 | 本次共检验电器25支，25支验电器合格。       |   |
| 142 | GX-B1328/20-3-24020       | 2024年3月28日 | 本次共检绝缘杆2套，2套绝缘杆合格。         |  |

|     |                     |            |                                                                 |                                                                                      |
|-----|---------------------|------------|-----------------------------------------------------------------|--------------------------------------------------------------------------------------|
| 143 | GX-B1328/20-3-24021 | 2024年3月27日 | 本次共检便携式接地和接地短路装置25套，25套便携式接地和接地短路装置合格。                          |   |
| 144 | GX-B1404/20-3-24008 | 2024年3月15日 | 所检电网谐波电压总谐波畸变率、各次谐波电压含有率、谐波电流符合GB/T 14549-1993 《电能质量 公用电网谐波》要求。 |   |
| 145 | GX-B1404/20-3-24009 | 2024年3月16日 | 所检电网谐波电压总谐波畸变率、各次谐波电压含有率、谐波电流符合GB/T 14549-1993 《电能质量 公用电网谐波》要求。 |  |